



Fire Inspection Checklist

A simple checklist to help ensure your facility is ready for inspection and emergency response.

- Fire extinguishers are properly installed and inspected
- Exit signs are illuminated and visible
- Emergency lighting functions during power loss
- Exit routes are unobstructed
- Required safety signage is installed
- Fire suppression systems are serviced and tagged
- Electrical panels are accessible and labeled
- Hazardous materials are stored safely
- Inspection and maintenance documentation is available